



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information

| | | |
|--|--------------------------|----------------|
| Vendor | | Listing Status |
| Honeywell International, Automation and Control Solution 1985 Douglas Drive N Golden Valley, MN 55422 USA | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of July 2009 | Revision 7 (135-2008) | July 2011 |

| | | |
|--|-----------------|------------------|
| Product Name | Model Number(s) | Software Version |
| Honeywell WEBs-AX Supervisor with BACnet-B-OWS | DR-NS-BAC-OWS | 3.6.35 |

Device Profiles

| | |
|-------------------------------------|---------------|
| Profile | Model Numbers |
| BACnet Operator Workstation (B-OWS) | DR-NS-BAC-OWS |

BIBBs Supported

| | | |
|--------------|-------------------------|----------|
| Data Sharing | ReadProperty-A | DS-RP-A |
| | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-A | DS-RPM-A |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-A | DS-WP-A |
| | WriteProperty-B | DS-WP-B |
| | WritePropertyMultiple-A | DS-WPM-A |
| | WritePropertyMultiple-B | DS-WPM-B |
| | COV-A | DS-COV-A |
| | View-A | DS-V-A |
| | Modify-A | DS-M-A |

| | | |
|-----------------|--------------------------------|--------|
| Alarm and Event | Alarm and Event-Notification-A | AE-N-A |
|-----------------|--------------------------------|--------|

| | | |
|------------|---|-----------|
| Management | Alarm and Event-ACK-A | AE-ACK-A |
| | Alarm and Event-View Notifications-A | AE-VN-A |
| | Alarm and Event-Advanced View Notifications-A | AE-AVN-A |
| | Alarm and Event-View and Modify-A | AE-VM-A |
| | Alarm and Event-Alarm Summary View-A | AE-AS-A |
| | Alarm and Event-Information-A | AE-INFO-A |

| | | |
|------------|------------------------------|------------|
| Scheduling | Scheduling-View and Modify-A | SCHED-VM-A |
|------------|------------------------------|------------|

| | | |
|----------|--------------------------------------|---------|
| Trending | Trending-View-A | T-V-A |
| | Trending-Automated Trend Retrieval-A | T-ATR-A |

| | | |
|-------------------------------|----------------------------------|----------|
| Device and Network Management | Dynamic Device Binding-A | DM-DDB-A |
| | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-A | DM-DOB-A |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationControl-B | DM-DCC-B |
| | ReinitializeDevice-B | DM-RD-B |
| | Automatic Device Mapping-A | DM-ADM-A |
| | Automatic Network Mapping-A | DM-ANM-A |
| | Automatic Time Synchronization-A | DM-ATS-A |
| | Manual Time Synchronization-A | DM-MTS-A |
| | Time Synchronization-A | DM-TS-A |
| | Time Synchronization-B | DM-TS-B |
| | UTC Time Synchronization-A | DM-UTC-A |
| | UTC TimeSynchronization-B | DM-UTC-B |
| | List Manipulation-A | DM-LM-A |
| | List Manipulation-B | DM-LM-B |

Object Type Support

| | | |
|--------|--|--|
| Device | | |
|--------|--|--|

Data Link Layer Options

| Media | Options |
|---------------------|---------|
| BACnet/IP (Annex J) | BBMD |
| Ethernet | |

Networking Options

| Networking Functionality | Media |
|--------------------------|--------------------------------|
| Router | BACnet/IP (Annex J) – Ethernet |

Character Set Support

| |
|--------------------------------|
| ANSI X3.4 ISO 10646 (UCS-2) |
|--------------------------------|