

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

# BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

#### **Listing Information**

Vendor		Listing Status
Honeywell International Inc. & HTSC-Beijing / SSL ACS-NPI 6B/F, Eagle Plaza, No. 26 Xiao Yun Rd, Chao Yang District Beijing 100125 China		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2011	Revision 9	May 2013

Product Name	Model Number(s)	Software Version
ComfortPoint <sup>™</sup> Open Digital I/O Controller	CPO-DIO	2.5.3

#### **Device Profiles**

Profile	Model Numbers
BACnet Advanced Automation Controller (B-AAC)	CPO-DIO

### **BIBBs Supported**

	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
Data Sharing	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-B	DS-COV-B

	Alarm and Event-Notification Internal-B	AE-N-I-B
Alarm and Event	Alarm and Event-ACK-B	AE-ACK-B
Management	Alarm and Event-Alarm Summary-B	AE-ASUM-B
	Alarm and Event-Information-B	AE-INFO-B

Scheduling	Scheduling Internal-B	SCHED-I-B
	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
5	DeviceCommunicationControl-B	DM-DCC-B
Device and Network	TimeSynchronization-B	DM-TS-B
Management	UTC TimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	List Manipulation–B	DM-LM-B
	Backup and Restore-B	DM-BR-B

## **Object Type Support**

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	File
Multi-state Value	Notification Class	Schedule

### **Data Link Layer Options**

Media	Options
MS/TP master	9600, 19200, 38400, 76800

### **Character Set Support**

ANSI X3.4 ISO 10646 (UCS-2)