



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
Honeywell ACS ECC 158 Nan Hai Road, TEDA, Tianjin, 300457, P.R.C People's Republic of China		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 4 (135-2004)	April 2013

Product Name	Model Numbers	Software Version
961 series BACnet Thermostat Driver	HT9611A3100, HT9612A3100, HT9611A2100, HT9612A2100, HT9611D3100, HT9612D3100, HT9611D2100, HT9612D2100	70.01 build 01
HT9631D Series Driver	HT9631D3100	01.00 build 01

### Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

### BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B

### Object Type Support

Analog Input	Analog Value
Binary Output	Device

### Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

### Character Set Support

ANSI X3.4 ISO 10646 (UCS-2)
--------------------------------