

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-30645)

Vendor		Listing Status
Honeywell International Inc. RMZ ECOWORLD INFRASTRUCTURE PVT. LTD. Survey #19/2, Devarabisanahalli Village, Varthur Hobli Bangalore East Taluk, Bangalore-560103 India		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of May 2018	Revision 14 (135-2012)	July 2018

Product Name	Model Numbers	Version
Honeywell ComfortPoint™ Open Plant Controller	CPO-PC410	3.1.10

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

BIBBs Supported

	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
Data Sharing	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Property-B	DS-COVP-B

	Notification Internal-B	AE-N-I-B
	Notification External-B	AE-N-E-B
Alarm and Event	Acknowledge-B	AE-ACK-B
Notification	Alarm Summary-B	AE-ASUM-B
Notification	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
	Event Log-Internal-B	AE-EL-I-B
Coboduling	Internal-B	SCHED-I-B
Scheduling	External-B	SCHED-E-B
	Viewing and Modifying Trends Internal-B	T-VMT-I-B
Trending	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B
	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
Device Management	UTCTimeSynchronization-B	DM-UTC-B
- - -	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-B	DM-OCD-B

Object Type Support

Accumulator	Analog Input	Analog Output
Analog Value	Binary Input	Binary Output
Binary Value	Calendar	Device
Event Enrollment	Event Log	File
Loop	Multi-State Input	Multi-State Output
Multi-State Value	Notification Class	Program
Schedule	Structured View	Trend Log

Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 76800, 115200
BACnet/IP (Annex J)	BACnet/IP, 'DIX' Ethernet

Character Set Support

1	
	ISO 10646 (UTF-8)
	ISO 10646 (UCS-2)
	100 10040 (000 2)