

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31027)

| Vendor | | Listing Status |
|--|--------------------------|----------------|
| Honeywell International Inc. RMZ ECOWORLD INFRASTRUCTURE PVT. LTD. Survey #19/2, Devarabisanahalli Village, Varthur Hobli Bangalore East Taluk, Bangalore-560103 India | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of May 2018 | Revision 14 (135-2012) | July 2018 |

| Product Name | Model Numbers | Firmware version |
|---|-------------------------|------------------|
| Honeywell ComfortPoint™ Open Plant Controller | CPO-PC500, CPO-PC600 | 4.1.9 |

Device Profiles

| Profile | Model Numbers |
|-----------------------------------|---------------|
| BACnet Building Controller (B-BC) | All models |

BIBBs Supported

| | ReadProperty-A | DS-RP-A |
|--------------|----------------------------|-----------|
| - | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-A | DS-RPM-A |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-A | DS-WP-A |
| Data Sharing | WriteProperty-B | DS-WP-B |
| | WritePropertyMultiple-A | DS-WPM-A |
| | WritePropertyMultiple-B | DS-WPM-B |
| | Change Of Value-A | DS-COV-A |
| | Change Of Value-B | DS-COV-B |
| | Change Of Value Property-B | DS-COVP-B |

| _ | Notification Internal-B | AE-N-I-B |
|-------------------|---|-----------|
| | Notification External-B | AE-N-E-B |
| Alarm and Event | Acknowledge-B | AE-ACK-B |
| Notification | Alarm Summary-B | AE-ASUM-B |
| Notification | Enrollment Summary-B | AE-ESUM-B |
| | Information-B | AE-INFO-B |
| | Event Log-Internal-B | AE-EL-I-B |
| | | |
| Cab a di dia a | Internal-B | SCHED-I-B |
| Scheduling | External-B | SCHED-E-B |
| | | |
| | Viewing and Modifying Trends Internal-B | T-VMT-I-B |
| Trending | Viewing and Modifying Trends External-B | T-VMT-E-B |
| | Automated Trend Retrieval-B | T-ATR-B |
| | | |
| | Dynamic Device Binding-A | DM-DDB-A |
| | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationControl-B | DM-DCC-B |
| | TimeSynchronization-B | DM-TS-B |
| Device Management | UTCTimeSynchronization-B | DM-UTC-B |
| | ReinitializeDevice-B | DM-RD-B |
| | Backup and Restore-B | DM-BR-B |
| | Restart-B | DM-R-B |
| | List Manipulation-B | DM-LM-B |
| | Object Creation and Deletion-B | DM-OCD-B |

Object Type Support

| Accumulator | Analog Input | Analog Output |
|-------------------|--------------------|--------------------|
| Analog Value | Binary Input | Binary Output |
| Binary Value | Calendar | Device |
| Event Enrollment | Event Log | File |
| Loop | Multi-State Input | Multi-State Output |
| Multi-State Value | Notification Class | Program |
| Schedule | Structured View | Trend Log |

Data Link Layer Options

| Media | Options |
|----------------------|-----------------------------------|
| BACnet/IP (Annex J) | BBMD |
| DACHEMIF (Allilex 3) | BACnet/IP, 'DIX' Ethernet |
| MS/TP Master | 9600, 19200, 38400, 76800, 115200 |

Character Set Support

| ICO 40646 (LITE 0) | |
|---------------------|--|
| ISO 10646 (UTF-8) | |
| 100 100 10 (1100 6) | |
| ISO 10646 (UCS-2) | |
| 100 100 10 (000 2) | |