

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

# **BACnet Testing Laboratories Product Listing**

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

#### **Listing Information (BTL-31355)**

Vendor		Listing Status
Honeywell International Inc. No. 158, Nan Hai Road, TEDA Tianjin, 300457 China		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of February 2024	Revision 16	November 2024

Product Name	Model Numbers	Firmware version
Honeywell TC300 Thermostats	TC300B-G, TC300C-G, TC320B-G, TC320C-G, TC320C-N, TC303B-G, TC321B-G, TC322B-G, TC300C-G1, TC320C-G1, TC303C-G, TC322C-G,	02.01.17.0/00.00.08.06

#### **Device Profiles**

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

#### **BIBBs Supported**

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B

Scheduling	Internal-B	SCHED-I-B
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
Device Management	TimeSvnchronization-B	DM-TS-B

UTCTimeSynchronization-B

ReinitializeDevice-B

List Manipulation-B

DM-UTC-B

DM-RD-B

DM-LM-B

### **Object Type Support**

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	Multi-State Value
Schedule		

#### **Data Link Layer Options**

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device
( )	BACnet/IP, 'DIX' Ethernet
MS/TP Master	9600, 19200, 38400, 57600, 76800, 115200

## **Character Set Support**

100 40040 (LITE 0)	
ISO 10646 (UTF-8)	
100 100 10 (011 0)	
ANCI VO A	
ANSI X3.4	
,	