



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information

Vendor		Listing Status
Honeywell International 1985 Douglas Drive Golden Valley, MN 55422 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of May 2005	Revision 2 (135-2001)	November 2006

Product Name	Model Number	Software Version
TB7600 series – Programmable or non-programmable multi-state thermostat for Roof Top or Heat Pump unit applications	TB7600A5014B	3.5.05 (tested v2.1.03)
	TB7600A5514B	
	TB7600B5014B	
	TB7600B5514B	
	TB7600H5014B	
	TB7600H5514B	
	TB7605B5014B	
	TB7605B5514B	
	TB7607B5014B	
	TB7607B5514B	
	TB7652A5014B	
	TB7652A5514B	
	TB7652B5014B	
	TB7652B5514B	
	TB7652H5014B	
	TB7652H5514B	
	TB7656B5014B	
TB7656B5514B		
TB7657B5014B		
TB7657B5514B		

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All Devices

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B

Object Type Support

Analog Input	Analog Value	Binary Input
Binary Value	Device	Multi-State Value
Group		

Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

Character Set Support

ANSI X3.4
