



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information

Vendor Honeywell Building Solutions 1985 Douglas Drive North Golden Valley, MN 55422-3992 USA		Listing Status Listed Product
Test Requirements Requirements as of August 2012	BACnet Protocol Revision Revision 10	Date Tested March 2013

Product Name	Model Number	Software Version
Din-Mon Advanced Meter	E-D5-x-05-x	06.52.01
Class 5000 Meter	E50-x-05-x	06.32.01
Class Green Net	E50-x-05-x	06.32.11
Class 3400 Meter	E34-x-05-x	06.12.01
Interval Data Recorder (IDR)	EIDR-x-05-x	06.42.01

Device Profiles

Profile	Model Numbers
BACnet Smart Sensor (B-SS)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	TimeSynchronization-B	DM-TS-B

Object Type Support

Analog Input	Device	
--------------	--------	--

Data Link Layer Options

Media	Options
BACnet IP (Annex J)	Register as Foreign Device

Character Set Support

UTF-8 / ANSI X3.4
