



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-30904)

Vendor		Listing Status
Honeywell International Inc. 12 Clintonville Rd Northford, CT 06472 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of February 2021	Revision 12 (135-2010)	December 2015

Product Name	Model Numbers	Firmware version
Honeywell Comfort Point™ Open IRM Controller	CPO-RL1, CPO-RL2, CPO-RL3, CPO-RL4, CPO-RL5, CPO-RL6, CPO-RL7U, CPO-RL8, CPO-RS1, CPO-RS2, CPO-RS3, CPO-RS4, CPO-RS5, CPO-RS6, AL-RL2, AL-RS4, CLMERL2, CLMERL6, CLMERL8, CLMERS4, CLMERS5, PCD7.LRL2, PCD7.LRS4, PCD7.LRS5, TR-RS4, TR-RS5	RX_v3.2.7.b1

Device Profiles

Profile	Model Numbers
BACnet Advanced Application Controller (B-AAC)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-B	DS-COV-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Acknowledge-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Information-B	AE-INFO-B
	Configurable Recipient Lists-B	AE-CRL-B

Scheduling	Internal-B	SCHED-I-B
------------	------------	-----------

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	List Manipulation-B	DM-LM-B

Object Type Support

Accumulator	Analog Input	Analog Output
Analog Value	Binary Input	Binary Output
Binary Value	Calendar	Device
File	Multi-State Value	Notification Class
Schedule		

Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 57600, 38400, 76800, 115200

Character Set Support

ISO 10646 (UCS-2)
ISO 10646 (UTF-8)