



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-30968)

Vendor		Listing Status
Honeywell 158 Nanhai Road, TEDA Tianjin China		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of February 2021	Revision 18	September 2022

Product Name	Model Numbers	Firmware version
Edge Control Series	ECx ¹ x ² -x ³ x ⁴ x ⁵ where x ¹ is C, D or E x ² is 100, 200 or 500 x ³ is C or P x ⁴ is E or R x ⁵ is number 0-9 or blank	2.0.7.10988

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC) BACnet Router (B-RTR) BACnet Broadcast Management Device (B-BBMD)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Property-B	DS-COVP-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Acknowledge-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
	Configurable Recipient Lists-B	AE-CRL-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Object Creation and Deletion-B	DM-OCD-B
	Router Configuration-B	NM-RC-B
	BBMD Configuration-B	NM-BBMD-C-B

Object Type Support

Analog Value	Binary Value	Bitstring Value
Calendar	Device	Event Enrollment
File	Multi-State Value	Network Port
Notification Class	Schedule	Trend Log

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD Register as Foreign Device BACnet/IP, 'DIX' Ethernet
MS/TP Master	9600, 38400, 115200, 19200, 57600
Ethernet	ISO 8802-3, 10BASET

Character Set Support

ANSI X3.4 ISO 10646 (UCS-2)
