



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
HRW Limited Unit 505, 5/F, Wai Wah Commercial Centre 6 Wilmer Street, Sai Ying Pun Hong Kong		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of July 2009	Revision 4 (135-2004)	July 2010

Product Name	Model Number(s)	Software Version
HP-BN Series	HPC8884BN HPC0662BN HPD0460BN HPD0460BNC HPD0460BNCT HPD0460BNT HPE8884BN HPE-BNMBUS HPE-BNMOD HPE-BNP1BUS HPV0662BN	4
HP-BN Series	HPAC-COP	4
HP-BN Series	HPE-BNSMA, HPE-BNPMAC	4
HP-BN Series	HPE-BNMR10	4

### Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Device		

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800
MS/TP slave	9600, 38400

## Character Set Support

ANSI X3.4
-----------