



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-30880)

| | | |
|--|--------------------------|----------------|
| Vendor | | Listing Status |
| Innotech 12 McKechnie Drive, Eight Mile Plains Brisbane, Queensland, 4113 Australia | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of January 2022 | Revision 16 | May 2022 |

| Product Name | Model Numbers | Firmware version |
|-----------------|--|------------------|
| SKIA Controller | SK8CD, SK8CE, SK8CM, SK8VD, SK8VE, SK8VM, SK8PM | 5.1.a.14 |

Device Profiles

| Profile | Model Numbers |
|--|---------------|
| BACnet Application Specific Controller (B-ASC) | All models |

BIBBs Supported

| | | |
|-------------------|-------------------------|----------|
| Data Sharing | ReadProperty-A | DS-RP-A |
| | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-A | DS-RPM-A |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-A | DS-WP-A |
| | WriteProperty-B | DS-WP-B |
| | WritePropertyMultiple-B | DS-WPM-B |
| | Change Of Value-A | DS-COV-A |
| Change Of Value-B | DS-COV-B | |

| | | |
|------------------------------|-------------------------|-----------|
| Alarm and Event Notification | Notification Internal-B | AE-N-I-B |
| | Acknowledge-B | AE-ACK-B |
| | Information-B | AE-INFO-B |

| | | |
|-------------------|------------------------------|----------|
| Device Management | Dynamic Device Binding-A | DM-DDB-A |
| | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationControl-B | DM-DCC-B |
| | TimeSynchronization-B | DM-TS-B |
| | ReinitializeDevice-B | DM-RD-B |
| | Restart-B | DM-R-B |

Object Type Support

| | | |
|--------------------|-------------------|--------------------|
| Analog Input | Analog Output | Analog Value |
| Binary Input | Binary Output | Binary Value |
| Device | Loop | Multi-State Input |
| Multi-State Output | Multi-State Value | Notification Class |

Data Link Layer Options

| | |
|---------------------|---|
| Media | Options |
| BACnet/IP (Annex J) | Register as Foreign Device BACnet/IP, 'DIX' Ethernet |
| MS/TP Master | 9600, 19200, 38400, 57600, 76800, 115200 |

Character Set Support

| |
|-------------------|
| ISO 10646 (UTF-8) |
|-------------------|