

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

# **BACnet Testing Laboratories**Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

#### **Listing Information (BTL-30756)**

Vendor		Listing Status
Johnson Controls 507 E. Michigan St Milwaukee, WI 53202 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of January 2020	Revision 18	August 2020

Product Name	Model Numbers	Firmware version
Variable Air Volume (VAV) Controllers	JC-VAV1717-0, JC-VAV1732-0	9.0.1.60

#### **Device Profiles**

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

### **BIBBs Supported**

	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
Data Sharing	WriteProperty-A	DS-WP-A
Data Sharing	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-B	DS-COV-B
	Change Of Value Property-B	DS-COVP-B
	Change Of Value Unsubscribed-B	DS-COVU-B

	Notification Internal-B	AE-N-I-B
	Acknowledge-B	AE-ACK-B
Alarm and Event	Alarm Summary-B	AE-ASUM-B
Notification	Enrollment Summary-B	AE-ESUM-B
Notification	Information-B	AE-INFO-B
	Event Log-Internal-B	AE-EL-I-B
	Configurable Recipient Lists-B	AE-CRL-B
	•	

Scheduling	Internal-B	SCHED-I-B
Scheduling	External-B	SCHED-E-B

Tranding	Viewing and Modifying Trends Internal-B	T-VMT-I-B
Trending	Automated Trend Retrieval-B	T-ATR-B

	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
Device Management	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B

## **Object Type Support**

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Device	File	Multi-State Value
Network Port		

## **Data Link Layer Options**

Media	Options
MS/TP Master	9600, 19200, 38400, 76800

## **Character Set Support**

	-
100 40040 (LITE 0)	
ISO 10646 (UTF-8)	
100 100 10 (011 0)	
100 40040 (1100 0)	
ISO 10646 (UCS-2)	
100 100 10 (000 =)	