



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31495)

Vendor		Listing Status
Johnson Controls 5757 N Green Bay Ave Glendale, WI 53209 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of February 2024	Revision 19 (135-2016)	December 2025

Product Name	Model Numbers	Firmware version
SNC Series of Network Control Engines, SNE Series of Network Engines	M4-SNE22000-0, M4-SNE11000-0, M4-SNE110L0-0, M4-SNE10500-0, M4-SNE22001-0, M4-SNE11001-0, M4-SNE110L1-0, M4-SNE10501-0, M4-SNE22002-0, M4-SNE11002-0, M4-SNE110L2-0, M4-SNE10502-0, M4-SNC25150-0, M4-SNC25150-0H, M4-SNC25150-04, M4-SNC25150-04H, M4-SNC16120-0, M4-SNC16120-0H, M4-SNC16120-04, M4-SNC16120-04H, M4-SNC25151-0, M4-SNC25151-0H, M4-SNC25151-04, M4-SNC25151-04H,	14.1.4.51

	M4-SNC16121-0, M4-SNC16121-0H, M4-SNC16121-04, M4-SNC16121-04H, M4-SNC25152-0, M4-SNC25152-0H, M4-SNC25152-04, M4-SNC25152-04H, M4-SNC16122-0, M4-SNC16122-0H, M4-SNC16122-04, M4-SNC16122-04H F4-SNC25150-0, F4-SNC25150-0H, F4-SNC25150-04, F4-SNC25150-04H, F4-SNC16120-0, F4-SNC16120-0H, F4-SNC16120-04, F4-SNC16120-04H, F4-SNC25151-0, F4-SNC25151-0H, F4-SNC25151-04, F4-SNC25151-04H, F4-SNC16121-0, F4-SNC16121-0H, F4-SNC16121-04, F4-SNC16121-04H, F4-SNC25152-0, F4-SNC25152-0H, F4-SNC25152-04, F4-SNC25152-04H, F4-SNC16122-0, F4-SNC16122-0H, F4-SNC16122-04, F4-SNC16122-04H	
--	--	--

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC) BACnet Secure Connect Hub (B-SCHUB) BACnet Router (B-RTR) BACnet Gateway (B-GW)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Property-A	DS-COVP-A
	Change Of Value Property-B	DS-COVP-B
	Change Of Value Unsubscribed-A	DS-COVU-A
	Change Of Value Unsubscribed-B	DS-COVU-B
	View-A	DS-V-A
	Advanced View-A	DS-AV-A
Modify-A	DS-M-A	
Advanced Modify-A	DS-AM-A	

Alarm and Event Notification	Notification-A	AE-N-A
	Notification Internal-B	AE-N-I-B
	Notification External-B	AE-N-E-B
	Acknowledge-A	AE-ACK-A
	Acknowledge-B	AE-ACK-B
	Alarm Summary-A	AE-ASUM-A
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-A	AE-INFO-A
	Information-B	AE-INFO-B
	View and Modify-A	AE-VM-A
	Advanced View and Modify-A	AE-AVM-A
	Alarm Summary View-A	AE-AS-A
	Event Log View-A	AE-ELV-A
	Event Log View and Modify-A	AE-ELVM-A
Configurable Recipient Lists-B	AE-CRL-B	

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B
	Advanced View and Modify-A	SCHED-AVM-A
	View and Modify-A	SCHED-VM-A
	Weekly Schedule-A	SCHED-WS-A

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B
	View-A	T-V-A
Advanced View and Modify-A	T-AVM-A	

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-A	DM-DCC-A
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-A	DM-TS-A
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-A	DM-UTC-A
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-A	DM-RD-A
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-A	DM-R-A
	Restart-B	DM-R-B
	List Manipulation-A	DM-LM-A
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-A	DM-OCD-A
	Object Creation and Deletion-B	DM-OCD-B
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Device Mapping-A	DM-ADM-A
	Automatic Time Synchronization-A	DM-ATS-A
	Manual Time Synchronization-A	DM-MTS-A
	Router Configuration-B	NM-RC-B
	BBMD Configuration-B	NM-BBMD-C-B
	Secure Connect Hub-B	NM-SCH-B
	Secure Connect Direct Connect-A	NM-SCDC-A
	Secure Connect Direct Connect-B	NM-SCDC-B
	Embedded Objects-B	GW-EO-B

Object Type Support

Accumulator	Analog Input	Analog Output
Analog Value	Averaging	Binary Input
Binary Output	Binary Value	Calendar
Device	Event Enrollment	File
Group	Loop	Multi-State Input
Multi-State Output	Multi-State Value	Network Port
Notification Class	Program	Schedule
Trend Log		

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD Register as Foreign Device BACnet/IP, 'DIX' Ethernet
MS/TP Manager	9600, 19200, 38400, 76800
BACnet/SC	Hub

Character Set Support

ISO 10646 (UTF-8) ISO 10646 (UCS-2) IBM/Microsoft DBCS
--