



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31555)

Vendor		Listing Status
Johnson Controls 32 Chang Jiang Rd, New District Wuxi, Jiangsu Province, 214028 China		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of June 2023	Revision 18	June 2024

Product Name	Model Numbers	Firmware version
EasyIO and EasyIO Neo Series Controller and EASI series Integrated Controller Actuator	FS-32, FS-20, FW-28, FW-14, FW-08, FW-08V, FW-VAV EC-1208, EC-1616, CW-0404, CW-0806, CW-1612 EC9305-HGA-VA, EC9305-HGA-MA, EC9310-HGA-VA, EC9310-HGA-MA, EC9320-HGA-VA, EC9320-HGA-MA, EC9335-HGA-VA, EC9335-HGA-MA, EC9305-HGA-VG, EC9305-HGA-MG, EC9310-HGA-VG, EC9310-HGA-MG, EC9320-HGA-VG, EC9320-HGA-MG, EC9335-HGA-VG, EC9335-HGA-MG, EC9305-HGA-AA, EC9310-HGA-AA,	2.1.38

	EC9320-HGA-AA, EC9335-HGA-AA	
--	---------------------------------	--

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Acknowledge-B	AE-ACK-B
	Information-B	AE-INFO-B
	Configurable Recipient Lists-B	AE-CRL-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B

Object Type Support

Analog Value	Binary Value	Calendar
Device	File	Multi-State Value
Network Port	Notification Class	Schedule
Trend Log		

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device BACnet/IP, 'DIX' Ethernet
MS/TP Manager	9600, 19200, 38400, 76800, 115200

Character Set Support

ISO 10646 (UTF-8) ISO 10646 (UCS-2)
--