



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of the BI.

## BACnet Testing Labs Product Listing

*This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
Johnson Controls CG-SP Europe Via Piave, 6 I-23781 Lomagna (LC) Italy		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of <b>May 2005</b>	135-2004	June 2007

Product Name	Model Number	Software Version
FX07, Terminal Unit Field Controller	LP-FX07D04-000C, LP-FX07D24-000C, LP-FX07D34-000C, LP-FX07D54-000C, LP-FX07D74-000C, LP-FX07D84-000C, LP-FX07A04-000C, LP-FX07A24-000C, LP-FX07A34-000C, LP-FX07A54-000C, LP-FX07A74-000C, LP-FX07A84-000C	Rev. 4.00
FX14, Field Controller	LP-FX14D14-000C, LP-FX14D24-000C, LP-FX14D64-000C, LP-FX14D74-000C	Rev. 4.00
FX16, Master Controller	LP-FX16X04-000C, LP-FX16X14-000C, LP-FX16X54-000C, LP-FX16X64-000C	Rev. 6.00

Product Name	Link to PICS on BI Website
FX07, Terminal Unit Field Controller	<a href="http://www.bacnetinternational.org/JCI/">http://www.bacnetinternational.org/JCI/</a>
FX14, Field Controller	<a href="http://www.bacnetinternational.org/JCI/">http://www.bacnetinternational.org/JCI/</a>
FX16, Master Controller	<a href="http://www.bacnetinternational.org/JCI/">http://www.bacnetinternational.org/JCI/</a>

## Device Profiles

Profile	Model Numbers
BACnet Advanced Application Controller (B-AAC)	All Devices

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	ACK-B	AE-ACK-B
	Information B	AE-INFO-B

Scheduling	Internal-B	SCHED-I-B
------------	------------	-----------

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Multi-State Value	Calendar	Event Enrollment
Device	Notification Class	Schedule

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

## Character Set Support

ANSI X3.4
-----------