



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
Building Efficiency 507 E. Michigan St Milwaukee, WI 53201 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of <b>July 2009</b>	Revision 7 (135-2008)	July 2011

Product Name	Model Number(s)	Software Version
Facility Explorer 4.1 BACnet Advanced Operator Workstation – B-AWS	LP-FXWSBACAW-0	3.6.47

### Device Profiles

Profile	Model Numbers
BACnet Advanced Operator Workstation (B-AWS)	LP-FXWSBACAW-0

### BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	View-A	DS-V-A
	Advanced View-A	DS-AV-A
	Modify-A	DS-M-A
Advanced Modify-A	DS-AM-A	

Alarm and Event Management	Alarm and Event-Notification-A	AE-N-A
	Alarm and Event-ACK-A	AE-ACK-A
	Alarm and Event-View Notifications-A	AE-VN-A
	Alarm and Event-Advanced View Notifications-A	AE-AVN-A
	Alarm and Event-View and Modify-A	AE-VM-A
	Alarm and Event-Advanced View and Modify-A	AE-AVM-A
	Alarm and Event-Alarm Summary View-A	AE-AS-A
Alarm and Event-Event Log View and Modify-A	AE-ELVM-A	

Scheduling	Scheduling-View and Modify-A	SCHED-VM-A
	Scheduling-Advanced View and Modify-A	SCHED-AVM-A
	Scheduling-Weekly Schedule-A	SCHED-WS-A

Trending	Trending-View-A	T-V-A
	Trending-Advanced View and Modify-A	T-AVM-A
	Automated Trend Retrieval-A	T-ATR-A

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	Automatic Device Mapping-A	DM-ADM-A
	Automatic Network Mapping-A	DM-ANM-A
	Time Synchronization-A	DM-TS-A
	Time Synchronization-B	DM-TS-B
	UTC Time Synchronization-A	DM-UTC-A
	UTC Time Synchronization-B	DM-UTC-B
	Automatic Time Synchronization-A	DM-ATS-A
	Manual Time Synchronization-A	DM-MTS-A
	DeviceCommunicationControl-A	DM-DCC-A
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-A	DM-RD-A
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-A	DM-BR-A
	Restart-A	DM-R-A
	Object Creation and Deletion-A	DM-OCD-A
List Manipulation-A	DM-LM-A	
List Manipulation-B	DM-LM-B	

## Object Type Support

Device		
--------	--	--

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD
Ethernet	

## Networking Options

Networking Functionality	Media
Router	BACnet/IP (Annex J) – Ethernet

## Character Set Support

ANSI X3.4 ISO 10646 (UCS-2)
--------------------------------