



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.*

### Listing Information (BTL-30374)

Vendor Johnson Controls, Inc. 507 E. Michigan St. Milwaukee, WI 53202 USA		Listing Status  Listed Product
Test Requirements Requirements as of May 2018	BACnet Protocol Revision Revision 12 (135-2010)	Date Tested November 2018

Product Name	Model Numbers	Software Version
Color Terminal Equipment Controller	TEC3612-x <sup>1</sup> -x <sup>2</sup> , TEC3613-x <sup>1</sup> -x <sup>2</sup> , TEC3622-x <sup>1</sup> -x <sup>2</sup> , TEC3623-x <sup>1</sup> -x <sup>2</sup> , TEC3630-x <sup>1</sup> -x <sup>2</sup> , TEC3631-x <sup>1</sup> -x <sup>2</sup>  Where x <sup>1</sup> is 13, 14, 15 or 16, and x <sup>2</sup> is 000 or 000G	10.3

### Device Profiles

Profile	Model Numbers
BACnet Advanced Application Controller (B-AAC)	All models

### BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-B	DS-COV-B
	Change Of Value Property-B	DS-COVP-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Acknowledge-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
----------	---	-----------

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Restart-B	DM-R-B
List Manipulation-B	DM-LM-B	

## Object Type Support

Analog Output	Analog Value	Binary Input
Binary Output	Calendar	Device
File	Multi-State Value	Notification Class
Schedule	Trend Log	

## Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 76800

## Character Set Support

ISO 10646 (UTF-8)
-------------------