



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-30522)

Vendor		Listing Status
Johnson Controls Inc. 507 E. Michigan St Milwaukee, WI 53202 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of May 2018	Revision 15	November 2018

Product Name	Model Numbers	Firmware version
Advanced Application Programmable Controller (PCA)	FX-PCA2513-0, FX-PCA3613-0	8.0.0.1248

Device Profiles

Profile	Model Numbers
BACnet Advanced Application Controller (B-AAC)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-B	DS-COV-B
	Change Of Value Property-B	DS-COVP-B
Change Of Value Unsubscribed-B	DS-COVU-B	

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Acknowledge-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
	Event Log-Internal-B	AE-EL-I-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B

Object Type Support

Accumulator	Analog Input	Analog Output
Analog Value	Binary Input	Binary Output
Binary Value	Calendar	Device
Event Log	File	Multi-State Value
Notification Class	Schedule	Trend Log

Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 76800

Character Set Support

ISO 10646 (UTF-8)
ISO 10646 (UCS-2)