



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BACnet International website.*

### Listing Information (BTL-25092)

Vendor KMC Controls, Inc 19476 Industrial Drive New Paris, IN 46553 USA		Listing Status
		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of July 2009	Revision 7 (135-2008)	August 2011

Product Name	Model Number	Software Version
SimplyVAV, Cooling/Heating	BAC-8001	R1.0.0.5
SimplyVAV, Fan & Reheat	BAC-8005	R1.0.0.5
SimplyVAV, Fan & Reheat, Position	BAC-8205	R1.0.0.5
SimplyVAV, Dual Duct	BAC-8007	R1.0.0.5
ASC for Titus VAV, SD Cooling Only	BAC-8001-03	R1.0.0.5
ASC for Titus VAV, SD Cooling Only	BAC-8201-03	R1.0.0.5
ASC for Titus VAV, Reheat and Fan	BAC-8005-03	R1.0.0.5
ASC for Titus VAV, Reheat and Fan	BAC-8205-03	R1.0.0.5
ASC for Titus VAV, DD	BAC-8007-03	R1.0.0.5
ASC for Titus VAV, DD	BAC-8207-03	R1.0.0.5
ASC RTU Controller	BAC-8304	R1.0.0.5
ASC RTU Controller	BAC-8304-56	R1.0.0.5

### Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All Devices

## BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Output	Binary Value	
Device	File	Loop
Multi-State Value	Program	

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

## Character Set Support

ISO 10646 (UTF-8), ANSI X3.4
------------------------------