



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

# BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

## Listing Information

Vendor		Listing Status
Lennox International, Inc. 1600 Metrocrest Dr. Carrollton TX 75006 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 7	April 2014

Product Name	Model Number	Software Version
Prodigy II Rooftop Unit controller	103957-01 (M3)	08.00.0570

## Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	103957-01 (M3)

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B

**Object Type Support**

Analog Input	Analog Output	Analog Value
Device		

**Data Link Layer Options**

Media	Options
MS/TP master	9600, 19200, 38400, 76800

**Character Set Support**

ANSI X3.4
-----------