



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31462)

Vendor		Listing Status
LOYTEC electronics GmbH Blumengasse 35 1170 Wien Austria		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2024	Revision 26	August 2025

Product Name	Model Numbers	Firmware version
BACnet Touch Panel	L-VIS Touch Panel: LVIS-3ME7-G1, LVIS-3ME7-G2, LVIS-3ME12-A1, LVIS-3ME15-A1, LVIS-3ME15-G1, LVIS 3ME15 G2, LVIS-3ME15-G3 LVIS7-32G1, LVIS7-32G2 LVIS12-32G1, LVIS12-32G2, LVIS12-32G3, LVIS15-32G1, LVIS15-32G2, LVIS15-32G3 LPAD-7 Programmable Touch Panel: LPAD7-31G2, LPAD7-41G2, LPAD7-31G3, LPAD7-41G3, LPAD7-31G4, LPAD7-41G4	8.6

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Property-A	DS-COVP-A
	Change Of Value Property-B	DS-COVP-B
	Change Of Value Unsubscribed-B	DS-COVU-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Notification External-B	AE-N-E-B
	Acknowledge-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
Configurable Recipient Lists-B	AE-CRL-B	

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-A	DM-TS-A
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-A	DM-UTC-A
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-A	DM-R-A
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-B	DM-OCD-B
	Automatic Time Synchronization-A	DM-ATS-A
	Slave Proxy-B	DM-SP-B
	Connection Establishment-A	NM-CE-A
	Router Configuration-B	NM-RC-B
	BBMD Configuration-B	NM-BBMD-C
	Foreign Device Registration-A	NM-FDR-A
	Secure Connect Hub-B	NM-SCH-B
	Secure Connect Direct Connect-A	NM-SCDC-A
Secure Connect Direct Connect-B	NM-SCDC-B	
Embedded Objects-B	GW-EO-B	

Object Type Support

Accumulator	Analog Input	Analog Output
Analog Value	Binary Input	Binary Output
Binary Value	Calendar	Characterstring Value
Device	Event Enrollment	File
Integer Value	Large Analog Value	Loop
Multi-State Input	Multi-State Output	Multi-State Value
Network Port	Notification Class	Octetstring Value
Positive Integer Value	Pulse Converter	Schedule
Trend Log		

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD Register as Foreign Device BACnet/IP, 'DIX' Ethernet
MS/TP Manager	9600, 19200, 38400, 76800, 115200
BACnet/SC	Hub Direct Connect

Character Set Support

ISO 10646 (UTF-8) ISO 8859-1 ISO 10646 (UCS-2)
--