

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

# **BACnet Testing Laboratories Product Listing**

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

#### **Listing Information (BTL-25106)**

Vendor		Listing Status
Macurco Inc. 1504 W 51st St Sioux Falls, SD 57104 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 12	February 2016

Product Name	Model Numbers	Software Version
Macurco Control Panel	DVP-120B DVP-120C	V3.302

#### **Device Profiles**

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

### **BIBBs Supported**

ReadProperty-A	DS-RP-A
ReadProperty-B	DS-RP-B
ReadPropertyMultiple-B	DS-RPM-B
WriteProperty-A	DS-WP-A
WriteProperty-B	DS-WP-B
WritePropertyMultiple-B	DS-WPM-B
COV-B	DS-COV-B
	ReadProperty-B ReadPropertyMultiple-B WriteProperty-A WriteProperty-B WritePropertyMultiple-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B

DeviceCommunicationControl-B	DM-DCC-B
ReinitializeDevice-B	DM-RD-B

## **Object Type Support**

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Multi-state Input	Multi-state Output	Multi-state Value
Device		

## **Data Link Layer Options**

Media	Options
MS/TP Master	9600, 19200, 38400, 57600, 76800, 115200

## **Character Set Support**

ICO 40646 (LITE 0)		
ISO 10646 (UTF-8)		
100 100 10 (011 0)		