



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information (BTL-24398)

Vendor		Listing Status
Mitsubishi Electric Europe B.V. UK Branch Travellers Lane, Hatfield Herts, AL10 8XB UK		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 12	May 2016

Product Name	Model Numbers	Software Version
Procon MelcoBEMS MINI (A1M)	Procon MelcoBEMS MINI (A1M)	3.0.11

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B

Object Type Support

Analog Input		Analog Value
Binary Input	Binary Output	Device
Multi-state Input	Multi-state Output	

Data Link Layer Options

Media	Options
MS/TP (master)	9600, 19200, 38400, 57600

Character Set Support

ISO 10646 (UTF-8)
