



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-30980)

Vendor		Listing Status
MSA Innovation, LLC 1100 Cranberry Woods Drive Cranberry Township, PA 16066 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of October 2016	Revision 16	April 2018

Product Name	Model Numbers	Firmware version
ProtoAir	FPA-W44, FPA-C34 FPA-C4x ⁰ where x ⁰ is 1,2 or 3	V6.40d (A)
ProtoCarrier	FPC-Cx ¹ where x ¹ is 34, 35, 41, 42 or 43	V6.40d (A)
ProtoCessor	FFP-ETH, FFP-485, FFP-LON	V6.40d (A)
ProtoNode	FPC-Nx ² where x ² is 34, 35,41,42, 43,54 or 64	V6.40d (A)
QuickServer	FS-QS-1x ³ , FS-QS-2x ⁴ -F where x ³ is 1011 or 1211 x ⁴ is 2110, 2210, 2310 or 2410	V6.40d (A)
EZ Gateway	FS-EZx ⁵ -x ⁶ -BAC where x ⁵ is 1,2,3 or 4 x ⁶ is MOD, MBUS, MBUS-MD	V6.40d (A)

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-B	DS-COV-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Acknowledge-B	AE-ACK-B
	Information-B	AE-INFO-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B
	List Manipulation-B	DM-LM-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Device	Life Safety Point	Multi-State Input
Multi-State Output	Multi-State Value	Notification Class
Trend Log		

Data Link Layer Options

Media	Options
Ethernet	ISO 8802-3, 10BASET

Character Set Support

ISO 10646 (UTF-8)
