



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-30340)

Vendor		Listing Status
OEMCtrl 1025 Cobb Place Boulevard Kennesaw, GA 30144 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of October 2016	Revision 12 (135-2010)	June 2018

Product Name	Model Numbers	Software Version
WebCTRL® for OEM	WC-OEM, WC-OEM1, WC-OEM10	7.0

Device Profiles

Profile	Model Numbers
BACnet Advanced Operator Workstation (B-AWS)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	View-A	DS-V-A
	Advanced View-A	DS-AV-A
	Modify-A	DS-M-A
Advanced Modify-A	DS-AM-A	

Alarm and Event Notification	Notification-A	AE-N-A
	Acknowledge-A	AE-ACK-A
	Alarm Summary-A	AE-ASUM-A
	Enrollment Summary-A	AE-ESUM-A
	Information-A	AE-INFO-A
	View Notifications-A	AE-VN-A
	Advanced View Notifications-A	AE-AVN-A
	View and Modify-A	AE-VM-A
	Advanced View and Modify-A	AE-AVM-A
	Alarm Summary View-A	AE-AS-A
	Event Log View-A	AE-ELV-A
Event Log View and Modify-A	AE-ELVM-A	

Scheduling	Advanced View and Modify-A	SCHED-AVM-A
	View and Modify-A	SCHED-VM-A

Trending	Automated Trend Retrieval-A	T-ATR-A
	View-A	T-V-A
	Advanced View and Modify-A	T-AVM-A

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-A	DM-DCC-A
	TimeSynchronization-A	DM-TS-A
	UTCTimeSynchronization-A	DM-UTC-A
	ReinitializeDevice-A	DM-RD-A
	Backup and Restore-A	DM-BR-A
	Object Creation and Deletion-A	DM-OCD-A
	Automatic Network Mapping-A	DM-ANM-A
	Automatic Device Mapping-A	DM-ADM-A
	Manual Time Synchronization-A	DM-MTS-A

Network Management	Connection Establishment-A	NM-CE-A
--------------------	----------------------------	---------

Object Type Support

Device		
--------	--	--

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device

Character Set Support

ISO 10646 (UTF-8)
