



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.*

### Listing Information (BTL-30207)

Vendor		Listing Status
OJ Electronics A/S Stenager 13B 6400 Sønderborg Denmark		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 12 (135-2010)	August 2017

Product Name	Model Numbers	Software Version
OJ-Air2	OJ-Air2Master  x-Air2Master where x is AD, AL, HA, MA, OJ, PE, PI, RH or TX  EX-Master	1.2

### Device Profiles

Profile	Model Numbers
BACnet Advanced Application Controller (B-AAC)	All models

### BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-B	DS-COV-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	ACK-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B

Scheduling	Internal-B	SCHED-I-B
------------	------------	-----------

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B

## Object Type Support

Analog Input	Analog Value	Binary Input
Binary Value	Calendar	Device
Notification Class	Schedule	

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD, Register as Foreign Device

## Networking Options

Networking Functionality	Media
BBMD	BACnet/IP (Annex J)

## Character Set Support

UTF-8
ISO 8859-1