



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-30884)

| | | |
|---|--------------------------|----------------|
| Vendor | | Listing Status |
| Packet Power L.L.C. 2716 Summer St. N.E. Minneapolis, MN 55413 USA | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of February 2021 | Revision 19 (135-2016) | April 2022 |

| | | |
|----------------------|---------------|--|
| Product Name | Model Numbers | Firmware version |
| Ethernet Gateway EG4 | EG4 | HEAD:1.1.23:0a9b258 (VR) main=5.48;iCast=0 (VD) |

Device Profiles

| | |
|---|---------------|
| Profile | Model Numbers |
| BACnet Gateway (B-GW) BACnet Smart Sensor (B-SS) | All models |

BIBBs Supported

| | | |
|--------------|------------------------|----------|
| Data Sharing | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-B | DS-WP-B |
| | Change Of Value-B | DS-COV-B |

| | | |
|-------------------|--------------------------|----------|
| Device Management | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |
| | ReinitializeDevice-B | DM-RD-B |
| | Virtual Network-B | GW-VN-B |

Object Type Support

| | | |
|--------------|--------|--------------|
| Analog Input | Device | Network Port |
|--------------|--------|--------------|

Data Link Layer Options

| | |
|---------------------|---|
| Media | Options |
| BACnet/IP (Annex J) | Register as Foreign Device BACnet/IP, 'DIX' Ethernet |

Character Set Support

| |
|-------------------|
| ISO 10646 (UTF-8) |
|-------------------|