



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Labs Product Listing

*This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
Philips Teletrol 286 Commercial St. Manchester NH 03101 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of <b>July 2009</b>	Revision 4 (135-2004)	October 2009

Product Name	Model Number	Software Version
VZ7656 Zoning System Rooftop Thermostat	TZC-Z7656B	1.02.00

## Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	TZC-Z7656B

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	COV-B	DS-COV-B

Scheduling	Readonly-B	SCHED-R-B
------------	------------	-----------

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B

## Object Type Support

Analog Input	Analog Value	Binary Input
Binary Value	Device	Multi-State Value
Schedule		

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

## Character Set Support

ANSI X3.4
-----------