



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of the BACnet Manufacturers Association (BMA). BTL is a registered trademark of the BMA.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BMA website.

Listing Information

| | | |
|---|--------------------------|----------------|
| Vendor | | Listing Status |
| Teletrol Systems Inc. 286 Commercial St. Manchester, NH 03101 | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of January 2002 | 135-1995b | January 2002 |

| | | |
|--------------|--------------|------------------|
| Product Name | Model Number | Software Version |
| eTRAC | 01-182 | Revision 1.00 |

| | |
|--------------|---|
| Product Name | Link to PICS on BMA Website |
| eTRAC | http://www.bacnetassociation.org/BMAProductCatalog/Teletrol/PICS/ETRAC/BMA_Catalog%20Listing_Teletrol_eTRAC.doc |

Device Profiles

| Profile | Model Numbers |
|------------------------------|---------------|
| BACnet Smart Sensor (B-SS) | 01-182 |
| BACnet Smart Actuator (B-SA) | 01-182 |

BIBBs Supported

| | | |
|--------------|-------------------------|----------|
| Data Sharing | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-B | DS-WP-B |
| | WritePropertyMultiple-B | DS-WPM-B |

| | | |
|-------------------------------|------|----|
| Device and Network Management | none | NA |
|-------------------------------|------|----|

Object Type Support

| | | |
|--------------|---------------|--------|
| Analog Input | Analog Output | Device |
| Binary Input | Binary Output | |

Data Link Layer Options

| Media | Options |
|-------------|--|
| MS/TP slave | baud rates: 115200, 76800, 57600, 38400, 28800, 19200, 14400, 9600, 4800, 2400 |

Character Set Support

| |
|-----------|
| ANSI X3.4 |
|-----------|