



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information

Vendor Powers A Watts Water Technologies Company 815 Chestnut Street North Andover MA 01845 USA		Listing Status Listed Product
Test Requirements Requirements as of November 2014	BACnet Protocol Revision Revision 10	Date Tested September 2015

Product Name Intelli-Station	Model Numbers 1069-01	Software Version J1245J
---------------------------------	--------------------------	----------------------------

Device Profiles

Profile BACnet Application Specific Controller (B-ASC)	Model Numbers All models
---	-----------------------------

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B

Object Type Support

Analog Input	Analog Value	
Binary Input	Device	

Data Link Layer Options

Media	Options
BACnet/IP	Register as a Foreign Device
MS/TP Master	9600, 19200, 38400, 57600, 76800, 115200

Character Set Support

ISO 10646 (UTF-8)
