



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-25116)

Vendor		Listing Status
AB Regin Box 116 SE-428 22 KÅLLERED Sweden		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2011	Revision 9	April 2013

Product Name	Model Number(s)	Software Version
Regio room controller series	RC-C3DOC RC-CDTO RC-CDFO RC-C3DFOC RCC-C3DOCS RCC-C3HCS	3.0.4

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B

Object Type Support

Analog Input	Analog Value	
Binary Input	Binary Value	Device
Loop	Multi-state Input	Multi-state Value

Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800
MS/TP slave	9600, 19200, 38400, 76800

Character Set Support

ANSI X3.4
IBM/Microsoft DBCS
JIS C 6226
ISO 10646 (UCS-4)
ISO 10646 (UCS-2)
ISO 8859-1