



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-25167)

Vendor		Listing Status
Reliable Controls Corporation 120 Hallowell Road Victoria, BC V9A 7K2 Canada		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of September 2014	Revision 9	May 2015

Product Name	Model Number(s)	Software Version
SMART-Space™ Controller	SSC, SSCE, SSCP, SSC2-32, SSC2-44, SSC2-45	8.10

Device Profiles

Profile	Model Numbers
BACnet General (B-GENERAL)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B

Scheduling	Schedule-Internal-B	SCHED-I-B
------------	---------------------	-----------

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Multiple Values Internal-B	T-VMMV-I-B

Device and Network Management	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B
	TimeSynchronization-B	DM-TS-B
	UTC TimeSynchronization-B	DM-UTC-B
	Backup and Restore-B	DM-BR-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Device	File	Loop
Multi-state Value	Program	
Schedule	Trend Log	Trend Log Multiple

Data Link Layer Options

Media	Options
MS/TP Slave	9600, 19200, 38400, 76800

Character Set Support

ANSI X3.4 / ISO 10646 (UTF-8)
