

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

# BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.

#### **Listing Information (BTL-30389)**

Vendor		Listing Status
Ruskin 3900 Dr. Greaves Road Kansas City, MO 64030 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of May 2018	Revision 14 (135-2012)	December 2018

Product Name	Model Numbers	Firmware version
Thermal Dispersion Probe Airflow Measuring System	TDP05K	1.5.1

#### **Device Profiles**

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

### **BIBBs Supported**

• •		
Data Charing	ReadProperty-B	DS-RP-B
Data Sharing	WriteProperty-B	DS-WP-B
Alarm and Event	Notification Internal-B	AE-N-I-B
=	Alarm Summary-B	AE-ASUM-B
Notification	Information-B	AE-INFO-B
		DM DDD 4
	Dynamic Device Binding-A	DM-DDB-A
Dovice Management	Dynamic Device Binding-B	DM-DDB-B
Device Management	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B

## **Object Type Support**

		N 40 4 61
Analog Value	L)evice	Notification Class
Alialog value	Device	Notification Class

## **Data Link Layer Options**

Media	Options
MS/TP Master	9600, 19200, 38400, 76800

### **Character Set Support**

ISO 10646 (UTF-8)		