



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information (BTL-30087)

Vendor SAMSON AG Weismüllerstraße 31 60314 Frankfurt a.M. GERMANY		Listing Status
		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 12 (135-2010)	October 2013

Product Name	Model Number	Software Version
TROVIS 6610 Automation Station	6610-0002	SAMSON BACstack 2.0

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	6610

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Notification External-B	AE-N-E-B
	ACK-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B Information B	AE-ESUM-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-A	DM-TS-A
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-A	DM-UTC-A
	UTCTimeSynchronization-B	DM-UTC-B
	Automatic Time Synchronization-A	DM-ATS-A
	Restart-A	DM-R-A
	Restart-B	DM-R-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	List Manipulation-B	DM-LM-B
Object Creation and Deletion-B	DM-OCD-B	

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	File
Event Enrollment	Loop	Notification Class
Multi-State Input	Multi-State Output	Multi-State Value
Pulse Converter	Schedule	Trend Log

Data Link Layer Options

Media	Options
BACnet IP (Annex J)	Register as Foreign Device, BBMD

Networking Options

Networking Functionality	Media
Annex J BBMD	BACnet/IP

Character Set Support

ANSI X3.4/UTF-8
ISO 10646 (UCS-4)
ISO 10646 (UCS-2)
ISO 8859-1