



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information

Vendor		Listing Status
Schneider Electric / Viconics 9245 Langelier Saint-Leonard, Qc, H1P 3K9 Canada		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of September 2014	Revision 10	June 2015

Product Name	Model Number	Software Version
SE8000 Series	SE8300U0B00, SE8300U0B11, SE8300U5B00, SE8300U5B11, SE8350U0B00, SE8350U0B11, SE8350U5B00, SE8350U5B11, SE8600U0B00, SE8600U0B11, SE8600U5B00, SE8600U5B11, SE8650U0B00, SE8650U0B11, SE8650U5B00, SE8650U5B11, SER8300A0B00, SER8300A0B11, SER8300A5B00, SER8300A5B11, SER8350A0B00, SER8350A0B11, SER8350A5B00, SER8350A5B11, SER8300A0B00LTD, SER8300A0B11LTD	1.3

VT8000 Series	VT8300U5000B, VT8300U5500B, VT8350U5000B, VT8350U5500B, VT8600U5000B, VT8600U5500B, VT8650U5000B, VT8650U5500B, VTR8300A5000B, VTR8300A5500B, VTR8350A5000B, VTR8350A5500B, VTR8300A5000BLTD	1.3
---------------	--	-----

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-B	DS-COV-B

Scheduling	Scheduling-Internal-B	SCHED-I-B
------------	-----------------------	-----------

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationsControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	CharacterString Value	Device
Multi-state Input	Multi-state Value	
Program	Schedule	

Data Link Layer Options

Media	Options
MS/TP	9600, 19200, 38400, 57600, 76800, 115200

Character Set Support

ISO 8859-1