



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31550)

Vendor		Listing Status
Schneider Electric 800 Federal Street Andover, MA 01810 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of December 2024	Revision 19 (135-2016)	April 2026

Product Name	Model Numbers	Firmware version
EcoStruxure Fire Operation	ES, FDP221, FDP252, FDP292	7.1.2

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Property-B	DS-COVP-B

Alarm and Event Notification	Notification-A	AE-N-A
	Notification Internal-B	AE-N-I-B
	Notification External-B	AE-N-E-B
	Acknowledge-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
Configurable Recipient Lists-B	AE-CRL-B	

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	Text Message-B	DM-TM-B
	TimeSynchronization-A	DM-TS-A
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-A	DM-UTC-A
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-B	DM-OCD-B
	Automatic Time Synchronization-A	DM-ATS-A
	Router Configuration-B	NM-RC-B
	BBMD Configuration-B	NM-BBMD-B
	Foreign Device Registration-A	NM-FDR-A
	Secure Connect Hub-B	NM-SCH-B
	Secure Connect Direct Connect-A	NM-SCDC-A
Secure Connect Direct Connect-B	NM-SCDC-B	
Embedded Objects-B	GW-EO-B	

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	Event Enrollment
File	Integer Value	Loop
Multi-State Input	Multi-State Output	Multi-State Value
Network Port	Notification Class	Schedule
Trend Log		

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD Register as Foreign Device BACnet/IP, 'DIX' Ethernet
MS/TP Manager	9600, 19200, 38400, 76800
BACnet/SC	Hub Direct Connect

Character Set Support

ANSI X3.4 ISO 8859-1 ISO 10646 (UCS-4) ISO 10646 (UCS-2) ISO 10646 (UTF-8)
--