



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information

Vendor		Listing Status
Schneider Electric LifeSpace 320 Tech Park Drive LaVergne, TN 37086 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 6	January 2013

Product Name	Model Number	Software Version
Schneider Electric Relay Panel LPB BACnet	SERPBC600	1.1

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationsControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B

Object Type Support

Binary Input	Binary Output	Device
--------------	---------------	--------

Data Link Layer Options

Media	Options
BACnet IP (Annex J)	Register as Foreign Device

Character Set Support

UTF-8 / ANSI X3.4
