



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor		Listing Status
Schneider Electric Buildings 1 High Street North Andover, MA 01845 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 6	July 2013

Product Name	Model Number	Software Version
Andover Continuum b3xxx Series	System Controller - b3608	4.5
	System Controller - b3624	4.5
	System Controller - b3800	4.5
	System Controller - b3804	4.5
	System Controller - b3810	4.5
	System Controller - b3814	4.5
	System Controller - b3920	4.5
	Terminal Controller - b3850	4.5
	Terminal Controller - b3851	4.5
	Terminal Controller - b3853	4.5
	Terminal Controller - b3865	4.5
	Terminal Controller - b3866	4.5
	Terminal Controller - b3867	4.5
	Terminal Controller - b3885	4.5
	Terminal Controller - b3887	4.5
	Terminal Controller - b3865-V	4.5
	Terminal Controller - b3866-V	4.5
Terminal Controller - b3885-V	4.5	

## Device Profiles

Profile	Model Numbers
BACnet Advanced Application Controller (B-AAC)	All Models

## BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B

Alarm and Event Management	Alarm and Event-Notification Internal-B	AE-N-I-B
	Alarm and Event-ACK-B	AE-ACK-B
	Alarm and Event-Information B	AE-INFO-B

Scheduling	Scheduling-Internal-B	SCHED-I-B
	Scheduling-External-B	SCHED-E-B

Trending	Viewing and Modifying Trends-Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Object Creation and Deletion-B	DM-OCD-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Command	Device
Event Enrollment	File	Loop
Multi-State Input	Multi-State Output	Multi-State Value
Notification Class	Program	Schedule
Trend Log		

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800

## Character Set Support

ANSI X3.4 ISO 8859-1
-------------------------