



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Labs Product Listing

*This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.*

### Listing Information

Vendor Schneider Electric Buildings and IT Business 839 North Perryville Road Rockford, IL 61107 USA		Listing Status  Listed Product
Test Requirements Requirements as of August 2012	BACnet Protocol Revision Revision 4 (135-2004)	Date Tested May 2013

Product Name	Model Number	Software Version
I/A Series® MicroNet™ Unitary Controller	MNB-300	1.432
I/A Series® MicroNet™ VAV Controller	MNB-V2	1.432
I/A Series® MicroNet™ VAV Controller	MNB-V1	1.432
I/A Series® MicroNet™ Zone Controller	MNB-70	1.432

### Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All Models

### BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Multi-State Output	Multi-State Value	Device

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19.2k, 38.4k, 76.8k
MS/TP slave	9600, 19.2k, 38.4k, 76.8k

## Character Set Support

ANSI X3.4
-----------