



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Labs Product Listing

This product has been tested at the BACnet Testing Labs and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information

Vendor Schneider Electric Buildings and IT Business 839 North Perryville Road Rockford, IL 61107 USA		Listing Status Listed Product
Test Requirements Requirements as of July 2009	BACnet Protocol Revision Revision 4 (135-2004)	Date Tested February 2012

Product Name I/A Series® MicroNet™ Plant Controller	Model Number MNB-1000	Software Version 1.515
--	--------------------------	---------------------------

Device Profiles

Profile BACnet Application Specific Controller (B-ASC)	Model Numbers MNB-1000
---	---------------------------

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Multi-State Value	Device	

Data Link Layer Options

Media	Options
BACnet IP (Annex J)	
Ethernet, ISO 8802-3	
MS/TP master	9600, 19.2k, 38.4k, 76.8k

Networking Options

Networking Functionality	Media
Router	BACnet/IP (Annex J), Ethernet, MS/TP
Annex J BBMD	BACnet/IP

Character Set Support

ANSI X3.4
