



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BI website.

Listing Information (BTL-30093)

Vendor Schneider Electric LLC 800 Federal Street Andover MA 01810 USA		Listing Status Listed Product
Test Requirements Requirements as of December 2011	BACnet Protocol Revision Revision 6	Date Tested May 2013

Product Name StruxureWare Building Operation Enterprise Server	Model Number(s) SW-ES	Software Version 1.3.0.20011
---	--------------------------	---------------------------------

Device Profiles

Profile BACnet Building Controller (B-BC)	Model Numbers SW-ES
--	------------------------

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	WriteProperty-A	DS-WP-A
	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
COV-B	DS-COV-B	

Alarm and Event Management	Alarm and Event-Notification Internal-B	AE-N-I-B
	Alarm and Event-ACK-B	AE-ACK-B
	Alarm and Event-Enrollment Summary-B	AE-ESUM-B
	Alarm and Event-Information-B	AE-INFO-B

Scheduling	Scheduling-Internal-B	SCHED-I-B
	Scheduling-External-B	SCHED-E-B

Trending	Viewing and Modifying Trends-Internal-B	T-VMT-I-B
	Viewing and Modifying Trends-External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-A	DM-TS-A
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Object Creation and Deletion-B	DM-OCD-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	Event Enrollment
File	Loop	
Multi-state Input	Multi-state Output	Multi-state Value
Notification Class	Schedule	Trend Log

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as a Foreign Device or BBMD

Character Set Support

ANSI X3.4
ISO 8859-1
ISO 10646 (UCS-4)
ISO 10646 (UCS-2)