



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information (BTL-30304-1)

| | | |
|--|--------------------------|----------------|
| Vendor | | Listing Status |
| Schneider Electric LLC 800 Federal Street Andover, MA 01810 USA | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of November 2014 | Revision 14 (135-2012) | April 2018 |

| Product Name | Model Numbers | Software Version |
|---------------------------|---|------------------|
| Network Management Card 2 | AP9635CH, AP9630, AP9631, AP9635, AP9630CH, AP9630J, AP9631CH, AP9631J, AP9635J | v6.5.7.b |

Device Profiles

| Profile | Model Numbers |
|--|---------------|
| BACnet Application Specific Controller (B-ASC) | All models |

BIBBs Supported

| | | |
|--------------|-------------------------|----------|
| Data Sharing | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-B | DS-WP-B |
| | WritePropertyMultiple-B | DS-WPM-B |
| | Change Of Value-B | DS-COV-B |

| | | |
|------------------------------|-------------------------|-----------|
| Alarm and Event Notification | Notification Internal-B | AE-N-I-B |
| | Information-B | AE-INFO-B |

| | | |
|-------------------|------------------------------|----------|
| Device Management | Dynamic Device Binding-A | DM-DDB-A |
| | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationControl-B | DM-DCC-B |

Object Type Support

| | | |
|--------------|-------------------|-----------------------|
| Analog Value | Binary Value | Characterstring Value |
| Device | Multi-State Value | Notification Class |

Data Link Layer Options

| | |
|---------------------|----------------------------|
| Media | Options |
| BACnet/IP (Annex J) | Register as Foreign Device |

Character Set Support

| |
|-------------------|
| ISO 10646 (UTF-8) |
|-------------------|