



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.*

### Listing Information

Vendor Setra Systems Inc. 159 Swanson Rd Boxboro MA 01719 USA		Listing Status  Listed Product
Test Requirements Requirements as of August 2012	BACnet Protocol Revision Revision 10	Date Tested January 2015

Product Name SRH200D and SRH300D	Model Number SRH200D, SRH300D	Software Version 1.8
-------------------------------------	----------------------------------	-------------------------

### Device Profiles

Profile BACnet Smart Sensor (B-SS)	Model Numbers All models
---------------------------------------	-----------------------------

### BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B

### Object Type Support

Analog Input	Device	
--------------	--------	--

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 57600, 76800, 115200

## Character Set Support

ISO 10646 (UTF-8)
-------------------