



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

## BACnet Testing Laboratories Product Listing

*BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.*

### Listing Information (BTL-30956)

Vendor		Listing Status
Shanghai Sunfull Automation Co. LTD Room 603, Building 25, Lane 8633, Zhongchun Road, Qibao Town, Minhang District, Shanghai China		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of May 2018	Revision 12 (135-2010)	August 2018

Product Name	Model Numbers	Version
SunFull BACnet Server (IO Module)	IOM12684, IOM8442, IOM8400, IOM16800, IOM16000, IOM0084	1

### Device Profiles

Profile	Model Numbers
BACnet Gateway (B-GW)	All models

### BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B

Device Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	Embedded Objects-B	GW-EO-B

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Device	Multi-State Input	Multi-State Output
Multi-State Value		

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BACnet/IP, 'DIX' Ethernet

## Character Set Support

ISO 10646 (UTF-8)
-------------------