



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

Listing Information

Vendor		Listing Status
Siemens Schweiz AG Gubelstrasse 22 6301 Zug, Switzerland		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 12	August 2015

Product Name	Model Number(s)	Software Version
DESIGO PXC001	PXC001.D MBUS, PXC001-E.D MBUS	6.0

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	WriteProperty-A	DS-WP-A
	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-A	DS-COV-A
	COV-B	DS-COV-B

Alarm and Event Management	Alarm and Event-Notification Internal-B	AE-N-I-B
	Alarm and Event-Notification External-B	AE-N-E-B
	Alarm and Event-ACK-B	AE-ACK-B
	Alarm and Event-Alarm Summary-B	AE-ASUM-B
	Alarm and Event-Enrollment Summary-B	AE-ESUM-B
	Alarm and Event-Information-B	AE-INFO-B
	Alarm and Event-Event Log-Internal-B	AE-EL-I-B
	Alarm and Event-Event Log-External-B	AE-EL-E-B

Scheduling	Scheduling Internal-B	SCHED-I-B
	Scheduling External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B
	Viewing and Modifying Multiple Values-Internal-B	T-VMMV-I-B
	Viewing and Modifying Multiple Values-External-B	T-VMMV-E-B
	Automated Multiple Value Retrieval-B	T-AMVR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-A	DM-TS-A
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-A	DM-UTC-A
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B
Object Creation and Deletion-B	DM-OCD-B	

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Command	Device
Event Enrollment	Event Log	File
Loop	Notification Class	Program
Multi-state Input	Multi-state Output	Multi-state Value
Accumulator	Pulse Converter	
Schedule	Trend Log	Trend Log Multiple
Load Control	Structured View	

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD

Character Set Support

ISO 10646 (UTF-8)