



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-30683-1)

| | | |
|--|--------------------------|----------------|
| Vendor | | Listing Status |
| Siemens Schweiz AG Theilerstrasse 1a 6300 Zug Switzerland | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of January 2020 | Revision 15 | December 2020 |

| Product Name | Model Numbers | Version |
|---|-----------------------|-----------------|
| DESIGO PXC4 and PXC5 Automation Station | PXC5.E003 | FW=02.11.02.155 |
| DESIGO PXC4 and PXC5 Automation Station | PXC4.M16, PXC4.E16 | FW=02.11.02.255 |

Device Profiles

| Profile | Model Numbers |
|---|---------------------|
| BACnet Building Controller (B-BC) | All models |
| BACnet Broadcast Management Device (B-BBMD) | PXC5.E003, PXC4.E16 |
| BACnet Router (B-RTR) | PXC5.E003 |

BIBBs Supported

| | | |
|--------------|--------------------------------|-----------|
| Data Sharing | ReadProperty-A | DS-RP-A |
| | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-A | DS-RPM-A |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-A | DS-WP-A |
| | WriteProperty-B | DS-WP-B |
| | WritePropertyMultiple-A | DS-WPM-A |
| | WritePropertyMultiple-B | DS-WPM-B |
| | Change Of Value-A | DS-COV-A |
| | Change Of Value-B | DS-COV-B |
| | Change Of Value Property-A | DS-COVP-A |
| | Change Of Value Unsubscribed-A | DS-COVU-A |
| | Change Of Value Unsubscribed-B | DS-COVU-B |

| | | |
|------------------------------|--------------------------------|-----------|
| Alarm and Event Notification | Notification-A | AE-N-A |
| | Notification Internal-B | AE-N-I-B |
| | Acknowledge-B | AE-ACK-B |
| | Alarm Summary-B | AE-ASUM-B |
| | Information-B | AE-INFO-B |
| | Event Log-Internal-B | AE-EL-I-B |
| | Configurable Recipient Lists-B | AE-CRL-B |

| | | |
|------------|------------|-----------|
| Scheduling | Internal-B | SCHED-I-B |
| | External-B | SCHED-E-B |

| | | |
|----------|---|-----------|
| Trending | Viewing and Modifying Trends Internal-B | T-VMT-I-B |
| | Automated Trend Retrieval-B | T-ATR-B |

| | | |
|-------------------|----------------------------------|-----------|
| Device Management | Dynamic Device Binding-A | DM-DDB-A |
| | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationControl-B | DM-DCC-B |
| | TimeSynchronization-A | DM-TS-A |
| | TimeSynchronization-B | DM-TS-B |
| | UTCTimeSynchronization-A | DM-UTC-A |
| | UTCTimeSynchronization-B | DM-UTC-B |
| | ReinitializeDevice-B | DM-RD-B |
| | Backup and Restore-B | DM-BR-B |
| | Restart-B | DM-R-B |
| | List Manipulation-B | DM-LM-B |
| | Automatic Time Synchronization-A | DM-ATS-A |
| | Manual Time Synchronization-A | DM-MTS-A |
| | Router Configuration-B | NM-RC-B |
| | BBMD Configuration-B | NM-BBMD-B |

Object Type Support

| | | |
|------------------------|--------------------|--------------------|
| Accumulator | Alert Enrollment | Analog Input |
| Analog Output | Analog Value | Binary Input |
| Binary Output | Binary Value | Calendar |
| Date Value | Datetime Value | Device |
| Event Log | File | Integer Value |
| Loop | Multi-State Input | Multi-State Output |
| Multi-State Value | Notification Class | Octetstring Value |
| Positive Integer Value | Program | Schedule |
| Structured View | Time Value | Trend Log |

Data Link Layer Options

| Media | Options |
|---------------------|---|
| BACnet/IP (Annex J) | Register as Foreign Device BACnet/IP, 'DIX' Ethernet |
| MS/TP Master | 9600, 19200, 38400, 76800, 115200 |

Character Set Support

| |
|---|
| ISO 10646 (UTF-8) IBM/Microsoft DBCS JIS X 0208 ISO 10646 (UCS-4) ISO 10646 (UCS-2) ISO 8859-1 |
|---|