

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

# BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

#### **Listing Information (BTL-30977)**

Vendor	Listing Status	
Siemens Theilerstrasse 1a 6300 Zug Switzerland		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of January 2020 Revision 15		March 2021

Product Name	Model Numbers	Firmware version
Desigo PXC3 and DXR2 Automation Stations	DXR2. $y^1$ - $y^2y^3y^4$ where $y^i$ is E18, M18, M11, E12, M12, E10, M10, E09, E09T, M09, M09T, E17C, or E17CX $y^2$ is null, P, or PX $y^3$ is 101, 102, or null $y^4$ is A, B, or null DXP2.E18-110BR, DXP2.M18-110BR PXC3. $z^1$ - $z^2$ where $z^i$ is E16A, E72, E72A, E75, or E75A $z^2$ is 100A or 200A	FW_V7.0_DXR2_V01.21.152. 8-OPENPORTS-3236 FW_V7.0_PXC3_V01.21.152. 8-OPENPORTS-3236

#### **Device Profiles**

Profile	Model Numbers		
BACnet Advanced Application Controller (B-AAC)	All models		

#### **BIBBs Supported**

Data Charing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
Data Sharing	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	•	
	Notification-A	AE-N-A
	Notification Internal-B	AE-N-I-B
Alarm and Event	Acknowledge-B	AE-ACK-B
Notification	Alarm Summary-B	AE-ASUM-B
Notification	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
	Event Log-Internal-B	AE-EL-I-B
_		
Scheduling	Internal-B	SCHED-I-B
Tranding	Viewing and Modifying Trends Internal-B	T-VMT-I-B
Trending	Automated Trend Retrieval-B	T-ATR-B
	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
Davisa Managament	TimeSynchronization-B	DM-TS-B
Device Management	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B

## **Object Type Support**

Alert Enrollment	Analog Input	Analog Output
Analog Value	Binary Input	Binary Output
Binary Value	Calendar	Command
Device	Event Enrollment	Event Log
File	Loop	Multi-State Input
Multi-State Output	Multi-State Value	Notification Class
Positive Integer Value	Program	Schedule
Structured View	Trend Log	

## **Data Link Layer Options**

Media	Options		
BACnet/IP (Annex J)	Register as Foreign Device		
BACHEVIF (Allilex 3)	BACnet/IP, 'DIX' Ethernet		
MS/TP Master	9600, 19200, 38400, 76800, 115200		

#### **Character Set Support**

ISO 10646 (UT	TF-8)			