

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

# **BACnet Testing Laboratories**Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

#### **Listing Information (BTL-31001)**

| Vendor  |                          | Listing Status |
|---|--------------------------|----------------|
| Siemens<br>Theilerstrasse 1a<br>6300 Zug<br>Switzerland |                          | Listed Product |
| Test Requirements                                       | BACnet Protocol Revision | Date Tested    |
| Requirements as of January 2022                         | Revision 15              | February 2023  |

| Product Name         | Model Numbers  | Firmware version |
|----------------------|----------------|------------------|
| Desigo BACnet Router | PXG3.M, PXG3.L | V01.21           |

#### **Device Profiles**

| Profile               | Model Numbers |
|-----------------------|---------------|
| BACnet Router (B-RTR) | All models    |

### **BIBBs Supported**

| Data Sharing | ReadProperty-A          | DS-RP-A  |
|--------------|-------------------------|----------|
|              | ReadProperty-B          | DS-RP-B  |
|              | ReadPropertyMultiple-B  | DS-RPM-B |
|              | WriteProperty-B         | DS-WP-B  |
|              | WritePropertyMultiple-B | DS-WPM-B |

| Device Management | Dynamic Device Binding-A     | DM-DDB-A |
|-------------------|------------------------------|----------|
|                   | Dynamic Device Binding-B     | DM-DDB-B |
|                   | Dynamic Object Binding-B     | DM-DOB-B |
|                   | DeviceCommunicationControl-B | DM-DCC-B |
|                   | TimeSynchronization-B        | DM-TS-B  |
|                   | UTCTimeSynchronization-B     | DM-UTC-B |
|                   | ReinitializeDevice-B         | DM-RD-B  |
|                   | Backup and Restore-B         | DM-BR-B  |
|                   | Restart-B                    | DM-R-B   |
|                   | List Manipulation-B          | DM-LM-B  |
|                   | Router Configuration-B       | NM-RC-B  |

## **Object Type Support**

| Device | File |  |
|--------|------|--|

## **Data Link Layer Options**

| Media               | Options                           |
|---------------------|-----------------------------------|
|                     | BBMD                              |
| BACnet/IP (Annex J) | Register as Foreign Device        |
|                     | BACnet/IP, 'DIX' Ethernet         |
| MS/TP Master        | 9600, 19200, 38400, 76800, 115200 |

## **Character Set Support**

| ISO 10646 (UTF-8 |  |  |
|------------------|--|--|