

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31062)

Vendor		Listing Status
Siemens Theilerstrasse 1a 6300 Zug Switzerland		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of January 2022	Revision 16	June 2023

Product Name	Model Numbers	Firmware version
Desigo PXC7, PXC5 and PXC4 Automation Station	PXC7.E400L, PXC7.E400M, PXC7.E400S, PXC5.E24, PXC5.E003, PXC4.E16, PXC4.E16S, PXC4.M16, PXC4.M16S	02.20.172.27

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models
BACnet Secure Connect Hub (B-SCHUB) BACnet Router (B-RTR) BACnet Broadcast Management Device (B-BBMD)	PXC7.E400L, PXC7.E400M, PXC7.E400S, PXC5.E24, PXC5.E003

BIBBs Supported

	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
Data Charing	WriteProperty-B	DS-WP-B
Data Sharing	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Property-A	DS-COVP-A
	Change Of Value Property-B	DS-COVP-B
	Change Of Value Unsubscribed-B	DS-COVU-B
	Notification-A	AE-N-A
	Notification Internal-B	AE-N-I-B
Alarm and Event Notification	Notification External-B	AE-N-E-B
	Acknowledge-B	AE-ACK-B
	Information-B	AE-INFO-B
	Event Log-Internal-B	AE-EL-I-B
	Configurable Recipient Lists-B	AE-CRL-B
Scheduling	Internal-B	SCHED-I-B
Scrieduling	External-B	SCHED-E-B
	Viewing and Modifying Trends Internal-B	T-VMT-I-B
Trending	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B

	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-A	DM-TS-A
	TimeSynchronization-B	DM-TS-B
Device Management	UTCTimeSynchronization-A	DM-UTC-A
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-B	DM-OCD-B
	Automatic Time Synchronization-A	DM-ATS-A
	Manual Time Synchronization-A	DM-MTS-A
	Router Configuration-B	NM-RC-B
	BBMD Configuration-B	NM-BBMDC-B
	Secure Connect Hub -B	NM-SCH-B

Object Type Support

Accumulator	Alert Enrollment	Analog Input
Analog Output	Analog Value	Binary Input
Binary Output	Binary Value	Calendar
Date Value	Datetime Value	Device
Event Enrollment	Event Log	File
Integer Value	Loop	Multi-State Input
Multi-State Output	Multi-State Value	Notification Class
Octetstring Value	Positive Integer Value	Program
Schedule	Structured View	Time Value
Trend Log		

Data Link Layer Options

Media	Options
	BBMD
BACnet/IP (Annex J)	Register as Foreign Device
, , ,	BACnet/IP, 'DIX' Ethernet
MS/TP Master	9600, 19200, 38400, 76800
BACnet/SC	Hub

Character Set Support

ISO 10646 (UTF-8)	
I ISO 10040 (UTF-8)	